

## 9. Maintenance

### 9.1 Error Code List

NO.	Malfunction Name	Display Method of Indoor Unit			A/C status	Possible Causes	
		Dual-8 Code Display	Indicator Display (during blinking, ON 0.5s and OFF 0.5s)				
			Operation Indicator	Cool Indicator	Heating Indicator		
1	High pressure protection of system	E1				<p>During cooling and drying operation, except indoor fan operates, all loads stop operation. During heating operation, the complete unit stops.</p> <p>Possible reasons:</p> <ol style="list-style-type: none"> <li>1. Refrigerant was superabundant;</li> <li>2. Poor heat exchange (including filth blockage of heat exchanger and bad radiating environment );</li> <li>Ambient temperature is too high.</li> </ol>	
2	Antifreezing protection	E2				<p>During cooling and drying operation, compressor and outdoor fan stop while indoor fan operates.</p> <ol style="list-style-type: none"> <li>1. Poor air-return in indoor unit;</li> <li>2. Fan speed is abnormal;</li> <li>3. Evaporator is dirty.</li> </ol>	
3	System block or refrigerant leakage	E3				<p>The Dual-8 Code Display will show E3 until the low pressure switch stop operation.</p> <ol style="list-style-type: none"> <li>1.Low-pressure protection</li> <li>2.Low-pressure protection of system</li> <li>3.Low-pressure protection of compressor</li> </ol>	
4	High discharge temperature protection of compressor	E4				<p>During cooling and drying operation, compressor and outdoor fan stop while indoor fan operates. During heating operation, all loads stop.</p> <p>Please refer to the malfunction analysis (discharge protection, overload).</p>	
5	Overcurrent protection	E5				<p>During cooling and drying operation, compressor and outdoor fan stop while indoor fan operates. During heating operation, all loads stop.</p> <ol style="list-style-type: none"> <li>1. Supply voltage is unstable;</li> <li>2. Supply voltage is too low and load is too high;</li> <li>3. Evaporator is dirty.</li> </ol>	
6	Communication Malfunction	E6				<p>During cooling operation, compressor stops while indoor fan motor operates. During heating operation, the complete unit stops.</p> <p>Refer to the corresponding malfunction analysis.</p>	
7	High temperature resistant protection	E8				<p>During cooling operation: compressor will stop while indoor fan will operate. During heating operation, the complete unit stops.</p> <p>Refer to the malfunction analysis (overload, high temperature resistant).</p>	
8	EEPROM malfunction	EE				<p>During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop</p> <p>Replace outdoor control panel AP1</p>	
9	Limit/ decrease frequency due to high temperature of module	EU				<p>All loads operate normally, while operation frequency for compressor is decreased</p> <p>Discharging after the complete unit is de-energized for 20mins, check whether the thermal grease on IPM Module of outdoor control panel AP1 is sufficient and whether the radiator is inserted tightly. If its no use, please replace control panel AP1.</p>	
10	Malfunction protection of jumper cap	C5				<p>Wireless remote receiver and button are effective, but can not dispose the related command</p> <ol style="list-style-type: none"> <li>1. No jumper cap insert on mainboard.</li> <li>2. Incorrect insert of jumper cap.</li> <li>3. Jumper cap damaged.</li> <li>4. Abnormal detecting circuit of mainboard.</li> </ol>	

NO.	Malfunction Name	Display Method of Indoor Unit			A/C status	Possible Causes	
		Dual-8 Code Display	Indicator Display (during blinking, ON 0.5s and OFF 0.5s)				
			Operation Indicator	Cool Indicator	Heating Indicator		
11	Gathering refrigerant	F0				When the outdoor unit receive signal of Gathering refrigerant ,the system will be forced to run under cooling mode for gathering refrigerant	
12	Indoor ambient temperature sensor is open/short circuited	F1				During cooling and drying operation, indoor unit operates while other loads will stop; during heating operation, the complete unit will stop operation.	
13	Indoor evaporator temperature sensor is open/short circuited	F2				AC stops operation once reaches the setting temperature. Cooling, drying: internal fan motor stops operation while other loads stop operation; heating: AC stop operation	
14	Outdoor ambient temperature sensor is open/short circuited	F3				During cooling and drying operating, compressor stops while indoor fan operates; During heating operation, the complete unit will stop operation	
15	Outdoor condenser temperature sensor is open/short circuited	F4				During cooling and drying operation, compressor stops while indoor fan will operate; During heating operation, the complete unit will stop operation.	
16	Outdoor discharge temperature sensor is open/short circuited	F5				During cooling and drying operation, compressor will stop after operating for about 3 mins, while indoor fan will operate; During heating operation, the complete unit will stop after operating for about 3 mins.	
17	Limit/ decrease frequency due to overload	F6				All loads operate normally, while operation frequency for compressor is decreased	
18	Decrease frequency due to overcurrent	F8				All loads operate normally, while operation frequency for compressor is decreased	

NO.	Malfunction Name	Display Method of Indoor Unit			A/C status	Possible Causes	
		Dual-8 Code Display	Indicator Display (during blinking, ON 0.5s and OFF 0.5s)				
			Operation Indicator	Cool Indicator	Heating Indicator		
19	Decrease frequency due to high air discharge	F9				All loads operate normally, while operation frequency for compressor is decreased Overload or temperature is too high; Refrigerant is insufficient; Malfunction of electric expansion valve (EKV)	
20	Limit/ decrease frequency due to antifreezing	FH				All loads operate normally, while operation frequency for compressor is decreased Poor air-return in indoor unit or fan speed is too low	
21	Voltage for DC bus-bar is too high	PH				During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop operation. 1. Measure the voltage of position L and N on wiring board (XT), if the voltage is higher than 265VAC, turn on the unit after the supply voltage is increased to the normal range. 2. If the AC input is normal, measure the voltage of electrolytic capacitor C on control panel (AP1), if its normal, theres malfunction for the circuit, please replace the control panel (AP1)	
22	Voltage of DC bus-bar is too low	PL				During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop 1. Measure the voltage of position L and N on wiring board (XT), if the voltage is higher than 150VAC, turn on the unit after the supply voltage is increased to the normal range. 2. If the AC input is normal, measure the voltage of electrolytic capacitor C on control panel (AP1), if its normal, theres malfunction for the circuit, please replace the control panel (AP1)	
23	Compressor Min frequency in test state	P0				Showing during min. cooling or min. heating test	
24	Compressor rated frequency in test state	P1				Showing during nominal cooling or nominal heating test	
25	Compressor maximum frequency in test state	P2				Showing during max. cooling or max. heating test	

NO.	Malfunction Name	Display Method of Indoor Unit			A/C status	Possible Causes
		Dual-8 Code Display	Indicator Display (during blinking, ON 0.5s and OFF 0.5s)			
26	Compressor intermediate frequency in test state	P3				Showing during middle cooling or middle heating test
27	Overcurrent protection of phase current for compressor	P5			During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop operation.	Refer to the malfunction analysis (IPM protection, loss of synchronism protection and overcurrent protection of phase current for compressor).
28	Charging malfunction of capacitor	PU			During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop	Refer to the part three—charging malfunction analysis of capacitor
29	Malfunction of module temperature sensor circuit	P7			During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop	Replace outdoor control panel AP1
30	Module high temperature protection	P8			During cooling operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop	After the complete unit is de-energized for 20mins, check whether the thermal grease on IPM Module of outdoor control panel AP1 is sufficient and whether the radiator is inserted tightly. If its no use, please replace control panel AP1.
31	Overload protection for compressor	H3			During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop operation.	1. Wiring terminal OVC-COMP is loosened. In normal state, the resistance for this terminal should be less than 1ohm. 2. Refer to the malfunction analysis (discharge protection, overload)
32	IPM protection	H5			During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop operation.	Refer to the malfunction analysis (IPM protection, loss of synchronism protection and overcurrent protection of phase current for compressor).
33	Module temperature is too high	H5				

NO.	Malfunction Name	Display Method of Indoor Unit			A/C status	Possible Causes
		Dual-8 Code Display	Indicator Display (during blinking, ON 0.5s and OFF 0.5s)			
34	Internal motor (fan motor) do not operate	H6				Internal fan motor, external fan motor, compressor and electric heater stop operation, guide louver stops at present location.
35	Desynchronizing of compressor	H7				During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop operation.
36	PFC protection	HC				During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop operation.
37	Outdoor DC fan motor malfunction	L3				Outdoor DC fan motor malfunction lead to compressor stop operation,
38	power protection	L9				compressor stop operation and Outdoor fan motor will stop 30s latter , 3 minutes latter fan motor and compressor will restart
39	Indoor unit and outdoor unit doesnt match	LP				compressor and Outdoor fan motor cant work
40	Failure start-up	LC				During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop operation.
41	Normal communication					
42	Defrosting			OFF 3S and blink once (during blinking, ON 10s and OFF 0.5s)	Defrosting will occur in heating mode. Compressor will operate while indoor fan will stop operation.	Its the normal state

NO.	Malfunction Name	Display Method of Indoor Unit			Display Method of Outdoor Unit			A/C status	Possible Causes	
		Dual-8 Code Display	Indicator Display (during blinking, ON 0.5s and OFF 0.5s)			Indicator has 3 kinds of display status and during blinking, ON 0.5s and OFF 0.5s				
			Operation Indicator	Cool Indicator	Heating Indicator	Yellow Indicator	Red Indicator	Green Indicator		
43	Malfunction of phase current detection circuit for compressor	U1							During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop	
44	Malfunction of voltage dropping for DC bus-bar	U3							During cooling and drying operation, compressor will stop while indoor fan will operate; During heating operation, the complete unit will stop	
45	Malfunction of complete units current detection	U5							During cooling and drying operation, the compressor will stop while indoor fan will operate; During heating operating, the complete unit will stop operation.	
46	The four-way valve is abnormal	U7							If this malfunction occurs during heating operation, the complete unit will stop operation. 1. Supply voltage is lower than AC175V; 2. Wiring terminal 4V is loosened or broken; 3. 4V is damaged, please replace 4V.	
47	Frequency limiting (power)					OFF 3S and blink 13 times				
48	Compressor is open-circuited				OFF 3S and blink once					
49	The temperature for turning on the unit is reached					OFF 3S and blink 8 times				
50	Frequency limiting (module temperature)					OFF 3S and blink 11 times				
51	Malfunction of zero-cross detection circuit	U8						The complete unit stops	1. Power supply is abnormal; 2. Detection circuit of indoor control mainboard is abnormal.	